#### Asian Nuclear Safety Network (ANSN) Regional Workshop on Site Evaluation for Small Modular Reactors (SMRs)

# **SMRs site selection and evaluation**

# in China

Haikou & Changjiang, China

06 - 10 November 2023



#### Characteristics of SMR

Overall SMR programme in China

Regulatory framework for SMR site

Progress in the Construction of Changjiang SMR

Future Opportunities and Challenges for SMR

# **Characteristics of SMR**

thermal power below 1000 megawatt and electrical power below 300 megawatt



modular design and construction concept, as well as passive safety technology

higher inherent safety feature, shorter construction period, and application flexibility than third-generation PWR



small, and its thermal energy storage during normal operation is small. It has less decay heat after shutdown



03

01

meet the needs of special field applications, such as thermal power supply



thermal supply for cities or industries, seawater desalination, hybrid energy,

By the end of Oct. 2023 (total)

• 19sites • 55 units in operation

#### • 24 units under construction



Distribution Map of NPPs in China Mainland

#### By the end of Oct. 2023

- **12** sites
- 24 units
- 22.807 GWe total installed capacity

#### 🥏 Units type

#### PWR:

$\succ$	10	HPR1000
$\sim$	Л	

- 4 VVER1200
- ➢ 2 CAP1400
- ▶ 4 CAP1000
- I SMR

NPP (under construction)	UNIT	RATED POWER
Haiyang	Unit 3	1x1253 MWe
Fangchenggang	Unit 4	1x1187 MWe
Tianwan	Unit 7&8	2x1265 MWe
Sanmen	Unit 3	1x1251 MWe
Zhangzhou	Unit 1&2	2x1212 MWe
State Nuclear Power Demonstration Project	Unit 1&2	2×1534 MWe
Taipingling	Unit 1&2	2x1202 MWe
Changjiang	<b>SMR 1</b> Unit 3&4	<b>1x125 MWe</b> 1x1197 MWe 1x1200 MWe
Sanao	Unit 1&2	2x1210 MWe
Xudapu	Unit 1,3&4	1x1253 MWe2x127 MWe
Lufeng	Unit 5	1x1200 MWe
Lianjiang	Unit 1	1x1253 MWe















High Temperature Gas Cooling Reactor **ACP100** 

Floating reactor Pool reactor

ACP100

Adopting an integrated PWR technology route with an output power of 125 megawatts

CNNC

Based on existing PWR technology and adopts a validated passive safety system

The first reactor demonstration project is carried out at the Changjiang Nuclear Power Plant in Hainan

The construction design of ACP100 project is near completion. The Preliminary Safety Assessment Report (PSAR) was completed in 2018.

CAP200

Passive pressurized water reactor with an output power of 200MWe

SPIC

Based on over 45 years of technical research and development experience and over 20 years of safe operation experience

The conclusion of research and development experience and achievements in the AP1000 unit and CAP1400

Absorbing the lessons learned from Fukushima accident and taking strengthened measures, the conceptual design was completed in 2015



Pool reactor with a thermal power of 400MW

Working at low temperature and atmospheric pressure. Incorporating inherent safty features

The water storage in the pool is large, with high thermal inertia, long response time, and robust to accidents

The possibility of core melting is very low, eliminating the possibility of a large amount of radioactive material release





#### A small modular offshore floating reactor

Aims at inherent safety feature and adaptability, modular design, and multipurpose applications

Provide a comprehensive supply of heat, electricity, and freshwater for marine resource development activities, energy supply to islands

The commonality between SMR and large PWR:

3 basic safety functions

- Controlling reactivity
- Removing heat from the core and spent fuel
- Containing radioactive materials, and limiting accident releases

SMR is a miniaturization of large PWR

SMR site evaluation mainly refer to large PWR

The safety regulations for site evaluation (HAF101)

Safety guidelines (HAD)

Applicant: Format and content of safety analysis report

**Reviewer: Standard review plan** 

Earthquakes (HAD101/01)

Atmospheric dispersion (HAD101/02)

Population distribution (HAD101/03)

External human events (HAD101/04)

Hydraulic dispersion (HAD101/05)

Hydrogeology (HAD101/06)

Site survey (HAD101/07)

riverside plant site flood control (HAD101/08)

coastal plant site flood control (HAD101/09)

extreme meteorological events (HAD101/10)

tropical cyclones (HAD101/11)

foundation safety (HAD101/12)

#### Basic factors and evaluation objectives that must be considered for site selection

• External natural and human events that may occur in the area where the site is located

• The characteristics of the site and the environment that affect the transfer of

radioactive substances to the human body

• The environmental factors related to the implementation of emergency measures

#### Basic criteria for site evaluation

- Follow the basic construction procedures for site selection.
- Investigate and evaluate site features (external natural and human events) that may affect safety, and determine design criteria.
- Investigate the environmental characteristics of areas that may be affected by radiation consequences under normal operating and accident conditions.
- Consider the storage and transportation of new fuel, spent fuel, and radioactive waste.
- Evaluate the potential changes that may occur during the lifespan of the plant site and environmental characteristics that affect safety within the plant site area.

Site location do not need ajecent to coastal or riverside

Adapt both to urban and rural areas

Using air coolent - no large water source required

No special geological conditions required

No special meteorological conditions required

No population size restrictions required

Robust to external events

#### **SMRs site selection and evaluation**



Regulatory standards and technical systems applicable to SMR are gradually establishing



Principles for Safety Evaluation of Small PWR Nuclear Power Plants For all important event sequences of design basis
accidents and beyond design basis accidents, the effective
dose and thyroid equivalent dose that individuals (adults)
may receive outside the small PWR nuclear power plant
should be lower than the intervention level of concealment
and iodine protection, respectively.

Conditions should be created for implementing off-site
emergency simplification or even canceling off-site
emergency response.



Guidelines for Land Base Small PWR Nuclear Emergency Works The recommended scope of the small PWR emergency planning area should not exceed 3 kilometers.

The specific scope should be proposed by the operating organization after systematic demonstration and scientific assessment, determined according to the prescribed

procedures.



Principles and Requirements for the Classification of Non residential Areas and Planned Restricted Areas for Small NPPs The scope of the emergency planning zone and

planned restricted area outside the small reaction yard

can be reasonably set according to the actual condition.

Explored the possibility of achieving the "three

zones integration" of small nuclear power plant sites,

emergency planning zones, and planned restricted

areas

#### **Layout of Hainan Changjiang Offshore Plant Site**



Serial Number	items	Unit	Parameters		
Main indicators					
1	Reactor type		IPWR		
2	Design life of power plant	Year	60		
3	Refueling cycle	Month	24		
4	4 Plant availability		>90		
5	Power plant operation mode		Mode A		
6	Rated thermal power of reactor core	MWt	385		
7	Unit rated power	MWe	~125		
8	8 Thermal efficiency (pure power generation, based on maximum continuous output)		>32		
9	Core damage frequency	/Reactor · year	<10-5		
10	10 Frequency of release of large amounts of radioactive substances		<10-6		
11	Occupational exposure collective dose	Person· Sv/ Reactor· Year	<0.5		
12	Ultimate Safe Ground Motion SL-2	g	0.30 (major equipment) 0.15 (others)		

#### **Site characteristics**

Reviewer domains	Important parameters	Design basis
Populations	Planning restricted areas emergency planning zone	Radius 5km Radius 3km
Seismic	seismic ground motion	The annual probability of exceedance 1.0E-4
Hydrological event	River flood	Probable maximum flood/The annual probability of exceedance 1.0E-4
	Oceanic flood	Probable maximum storm surge + astronal tide
Meteorological	Rainfall Extreme Wind Snow load Extreme temperature Tornado wind	Probable maximum precipitation 100 years return periods 100 years return periods 100 years return periods The annual probability of exceedance 1.0E-7
Human induced events	Explosion Aircraft crash	According the source item distribution The exclusion annual probability of exceedance 1.0E-7,
Geotechnical	landslide stability of foundation	According to site situation & survey According to site characteristic & engineering survey



#### **Future Opportunities and Challenges for SMR**



- Industry planning
- Policy guidance
- Public communication
- International cooperation



# **Thanks for Your Attention**

**Questions & Comments**